


# rejuWATER™ STP RETROFIT



The information on this page may contain confidential and/or privileged material belonging to riteways. Any unauthorized review, use, disclosure, dissemination, forwarding, printing or copying of this is strictly prohibited and may be unlawful

Initials

Date

Code

Modifications

No

	Parameter	
1	Each unit dimensions:	400 wide x 600 long x ~700 height (mm)
2	Material of construction	Heavy duty plastic crates
3	Capacity of each unit	1000 litres per day (1 KLD)
4	Inlet BOD / Outlet BOD (mg/L)	~400 / ~10
5	Flow rate	60 to 100 LPH
6	Retrofit design	Modular integration

Date	Prpd by	Aprd by	Scale
22-12-2010	BN	NS	Not to scale

Tel: 2345 2279  
Fax: 080 2838 1050  
[sales@rite-ways.com](mailto:sales@rite-ways.com)  
[www.rite-ways.com](http://www.rite-ways.com)



## rejuWATER™ Specifications

riteways company reserves the right to incorporate any modifications or improvements in mounts and mount specifications which it considers necessary and information may change without notice. It does not assume any obligation to make said changes in mounts previously sold. riteways is not responsible for misprints or typographical errors.

ID :

SS13